



Facility Name: Rydges Plaza Cairns

Facility Type: Hotel/Resort

**Facility Address: Cnr Grafton & Spence Streets
PO Box 858, Cairns**

**Phone: 07 4046 0300 – within Australia
+61 7 4046 0300 – International**

**Fax: 07 4046 0333 – within Australia
+61 7 4046 0333 – International**

Email: daniel_meek@rydges.com

Web: www.rydges.com

Room numbers: one accessible room no interconnecting room

Recommended:

Recommended for ambulant and wheel chair users with a high level of function.

Parking:

There are no designated accessible parking bays in the car park on the second floor, but there is a drop off area under cover beside the reception.



Entry into reception

Entry into reception is through double automatic doors measuring 2200mm wide, leading into a large level tiled area with ample seating. The reception desk does not have a lowered section for wheel chairs but staff are very friendly and will assist where necessary.

Access to public areas



Entry into the restaurant and bar is all level, but access to the pool is up stairs.

Accommodation:

The accessible guest room is on the fourth floor. The door into the lift is 970mm wide and the internal measurement of the lift is 1300mm wide and 1890mm long. There is no verbal announcement for stops at each floor and the buttons are not Braille, but are raised.



The door handle is a D handle, with a clear opening width of 850mm, but is unable to be opened with one hand and requires some force.



Room furniture can be moved to suit the guest's requirements, just notify staff when booking and they will be more than happy to assist. The bed room has one queen size bed with the widest space at the side of the bed being 2110mm. Under bed clearance is 95mm and the height to the top of mattress is 610mm.



There is a writing desk provided with a height to the top of the desk at 740mm and clear height from the floor of 610mm.

There is a coffee/tea making facility in the room.

The TV can be controlled by remote from the bed.

The height of the cupboard clothes rail is 1610mm above the floor.

The height of the light switches is 930mm from the floor.

Sanitary Facilities:

Entry into the accessible shower and toilet is up a 3cm lip and through a 845mm clear opening door. The facility is a combined toilet and shower with a dimension of 1670mm long by 2190mm wide.



Lip leading to the bathroom.



There are vertical and horizontal grab rails fitted beside the toilet which measure 765mm from the floor. The toilet measures 460mm from the wall to the centre of the toilet seat and the seat is 450mm from the floor.



There is a water sill between the toilet and the shower, which would be easy to roll over.

The shower has both vertical and horizontal grab rails, the shower rose is mounted high and is not on a sliding rail but can be removed and used while seated.

Clearance to the under side of the sink is 680mm with a height to top of sink at 845mm. The base of the mirror from floor is 940mm.




Diagram not to scale.

General:

Staff are very friendly and will assist with baggage if required.

There is no emergency call system in the bathroom.

Assistance dogs are welcome on the premises.